

This brief is being provided to inform the board, staff, and public of the details of an agenda item that requires no action from the board. The President of the Board will provide board members, staff, and the public the opportunity to ask questions about this topic when this agenda item is announced.

Date: 9/12/2022

Originator: Assistant GM/Lead Operator

Agenda Topic Title: Field Report

Purpose of Brief: Informational Briefing

Supporting Documents Included: No

Water Distribution System:

- Wells Productions for Aug 2022 1,246,813 Gal
- Booster Stations – BS#4 has had several low-pressure events.
- Tanks – Exterior of Storage Tanks are slowly rusting Needs to be repainted in spring of 2023

Sewer Transmission System and Septic Tanks:

- Leach Fields - Falling Water Leach field expansion nearing completion. The new leach field trenches will be online around Oct 1st CV Salts Update, we have been collecting data for the last few months our sample site at Falling Water Leach Field CV Salts average is about 810 PPM for this month (Maxum Contaminant level) is 700 PPM. Falling Water Wastewater Treatment Plant Pipeline Power Point.
- The Septic tanks - pumping program is completed.

Propane System update:

- Report and Power Point.